



SHERWIN-WILLIAMS ITALY

Società a Responsabilità Limitata

via del Fiffò 12
I -40065 - Pianoro (BO)

PRODUCT CERTIFICATE CSEW PLUS n° 15

We hereby certify the conformity of the coating system

SAYERLACK

HYDROPLUS IMPREGNATING STAIN
AM0504/XX*
(one layer)

+

HYDROPLUS TOP COAT AZ3530/XX**
(one layer - minimum wet film thickness 300 micron)

to the EN 927-2:2006 performance specification and
to the additional requirements of the technical rules of the

CATAS QUALITY AWARD
COATING SYSTEM FOR EXTERIOR WOOD

("STABLE" PRODUCTS)
rev. 14 dated 18.01.2022

THE USE OF THE WORD **PLUS** INDICATES THAT THE CERTIFIED COATING SYSTEM SATISFIES THE
NATURAL WEATHERING TEST REQUIREMENTS FOR AN EXPOSURE TIME
TWICE AS LONG AS THAT REQUIRED BY EN 927-3 (2 YEARS).

* IMPREGNATING STAIN COLOURS

51 CHESTNUT	84 BRENNER WALNUT	88 BROWN WALNUT	92 WALNUT
-------------	-------------------	-----------------	-----------

** TOP COAT SHADES

89 TEAK	70 HONEY	88 HAZELNUT	92 WALNUT
---------	----------	-------------	-----------

March 14th 2022

FIRST ISSUE

May 13th 2022

CURRENT ISSUE

December 31st, 2025

VALID UNTIL

dr. Franco Bulian
Managing Director

This document is validated by digital signature and time stamping in accordance with the Italian laws and the European Directives which regulate the electronic signature systems.

CATAS S.p.A.

Iscr. Reg. Imprese Udine
nr.iscr. C.F. 01818850305

Reg. Impr. UD 20663

P.IVA 01818850305

C.Soc. 984.250,00 Euro i.v.

Sede: Via Antica 24/3

San Giovanni al Natisone 33048 (UD)

cqa@catas.com